

23 January 2002

Mr Jonathan Berry  
ECO Design – Greywater Recycling & Irrigation Systems  
PO Box 2000  
Fairfield Gardens QLD 4103

Dear Mr Berry,

**ECO Design Greywater Recycling System (GRS)**


I refer to your submission dated 8 November 2001, in which you requested NSW Health accreditation for the ECO Design Greywater Recycling System.

In NSW the GRS is classified as a greywater diversion device (GDD) as set out in the NSW Health Department 's policy document called "Greywater Reuse in sewerred single domestic premises", dated April 2000.

A greywater diversion device and the associated land application system do not require accreditation by NSW Health. However an approval to operate a greywater diversion device and the land application system needs to be obtained from the Local Authority prior to the installation of the device.

Should you require any further information on these matters please contact Mr Tony Bles on telephone: (02) 9816 0360 or fax: (02) 9816 0377.

Yours faithfully,



A.J. Bles  
**Senior Policy Analyst**